



NOTES:

1. FOR TOP SECTION OF 3/4" -1" ASSEMBLY, A QUAZITE COMPOSOLITE (PG1730BB18) BOX IS REQUIRED. FOR BOTTOM SECTION OF 3/4" -1" ASSEMBLY, A QUAZITE COMPOSOLITE (PG1730BB12) BOX IS REQUIRED.
2. FOR 3/4"-1" ASSEMBLY A TRAFFIC COVER (PG1730HA0009) IS REQUIRED.
3. FOR 1-1/2" -2" ASSEMBLY, A QUAZITE COMPOSOLITE (PG2436BB18-BOTH SECTIONS) BOX WITH A TRAFFIC COVER (PG2436HA0009) IS REQUIRED.
4. DRAIN TO ATMOSPHERE WHEN APPLICABLE.

**DAVIDSON WATER INC.**  
**WELCOME, NORTH CAROLINA**  
**BACKFLOW PREVENTION**

BACKFLOW PREVENTION  
 STANDARD DETAIL

DOUBLE CHECK VALVE  
 ASSEMBLY (DC) 3/4"-2"  
 BELOW GROUND  
 TRAFFIC INSTALLATION

SCALE: NOT TO SCALE  
 REVISED: 10/12/07