

Facilities Requiring Protection

1. Aircraft and Missile Plants: RP

2. Automotive service stations, dealerships, etc.

- a. No health hazard: DCVA
- b. Health hazard: RP

3. Automotive Plants: RP

4. Auxiliary Water Systems:

- a. Approved public/private water supply: DCVA
- b. Unapproved public/private water supply: AG
- c. Used water and industrial fluids: RP

5. Bakeries:

- a. No health hazard: DCVA
- b. Health hazard: RP

6. Battery Manufacturers: RP

7. Beauty Shops/barber Shops:

- a. No health hazard: DCVA
- b. Health hazard: RP

8. Beverage Bottling Plants:

- a. No health hazard: DCVA
- b. Health hazard (back pressure): RP

9. Breweries: RP

10. Buildings-hotels, apartment houses, public and private buildings, or other structures having unprotected cross-connections.

- a. Under five stories no health hazard: DCVA
- b. Under five stories health hazard: RP
- c. Over five stories all: RP

11. Canneries, packing houses, and rendering plants: RP

12. Car Wash Facilities: RP

13. Chemical Plants—manufacturing, processing, compounding or treatment: RP

14. Chemically Contaminated Water Systems: RP

15. Commercial Car-wash Facilities: RP

16. Commercial Greenhouses: RP

17. Commercial Kitchens: RP

a. Warming Kitchen: DCVA

18. Commercial Sales Establishments (department stores, malls, etc.)

a. No health hazard: DCVA

b. Health hazard: RP

19. Connection to Tanks, lines and vessels that handle non-toxic substances:

a. Handle non-toxic substances: DCVA

b. Have pumps, lines, steam boilers or vessels that handle sewage, lethal substances, toxic or radioactive substances: RP

20. Cooling Systems: Open or Closed: RP

21. Concrete/Asphalt Plants: RP

22. Dairies and Cold Storage Plants: RP

23. Dye Works: RP

24. Exterminators and lawn care companies: RP

25. Film Laboratories: RP

26. Fire Systems:

a. Systems three-fourths inch to two inches:

i. No health hazard: DCVA (With meter or detector meter)

ii. Health hazard: (booster pumps, foam, antifreeze solution, FDC, etc.): RP (With meter or detector meter)

b. Systems two and one half inches and larger:

i. No health hazard: DCVA (detector meter)

ii. Health hazard: (booster pumps, foam, antifreeze solution, FDC, etc.): RP (detector meter)

27. Green House – Nursery: RP

28. Hospitals, Medical Buildings, Sanitariums, Morgues, Mortuaries, Autopsy Facilities, Nursing and Convalescent Homes, Medical Clinics, and Veterinary Hospitals: RP

29. Industrial Facilities:

- a. No health hazard: DCVA
- b. Health hazard: RP

30. Laundries:

- a. No health hazard: DCVA
- b. Health hazard: RP

31. Lawn Irrigation Systems: RP

32. Metal Manufacturing, metal plating, metal; cleaning, processing, and fabricating plants: RP

33. Mobile Home Parks:

- a. No health hazard: DCVA
- b. Health hazard: RP

34. Oil and gas production, storage or transmission properties: RP

35. Paper and Paper Products Plants: RP

36. Pest Control: RP

37. Plating Plants: RP

38. Power Plants: RP

39. Radioactive materials or substances plants or facilities handling: RP

40. Reclaimed or Recycled Water: RP

41. Restaurants: RP

42. Restricted, classified, or other closed facilities: RP

43. Rubber Plants: RP

44. Sand and Gravel Plants: RP

45. Schools and Colleges: RP

46. Sewage and Storm Drain Facilities: RP

47. Swimming Pools: RP

48. Veterinary Hospitals or Clinics: RP

49. Wastewater Treatment Plants: RP

50. Waterfront Facilities and Industries: RP